

RECALL SAFETY NOTICE

Risk: Fire Hazard

Potential damage from overheating and fire to appliances or other equipment



Square D QO™ Plug-On Neutral Load Centers also known as Load Centers, Breaker Boxes, Electric Panels

Manufactured February 2020 – January 2022



Indoor Load Center



Outdoor Load Center

Within affected QO Plug-On Neutral Load Centers, the wire binding screw may not be fully tightened to the neutral bar.

Free inspection and repair for recalled product shall be provided.

Instructions on how to inspect the load center can be found at <https://se.com/us/qoloadcenter-safetyrecallnotice> For more information contact Schneider Electric Customer Care.

- By phone at 1-888-778-2733; option 2,1,4 from 8AM-5PM EST
- Chat <https://www.se.com/us/en/work/support/customer-care/contact-schneider-electric.jsp>
- Visit: <https://se.com/us/qoloadcenter-safetyrecallnotice>

Post until October 28, 2022

In cooperation with the U.S. Consumer Product Safety Commission